




A direct successor
to the



George Westinghouse

Westinghouse
Iso Phase Bus

Plant in Cinn Ohio



Certificate of Registration

This certifies that the Quality Management System of

Crown Electric Engineering & Manufacturing LLC

175 Edison Drive
Middletown, Ohio, 45044, United States

has been assessed by NSF-ISR and found to be in conformance to the following standard(s):

ISO 9001:2008

Scope of Registration:

Design, fabrication, assembly, installation and refurbishment of isolated phase bus; bus duct; custom NEMA enclosures; switchgear; match and line; power houses; transformer and generator throats; forced air cooling units and fabrication and assembly of customer parts and systems.



Certificate Number: C0164276-IS3
Certificate Issue Date: 26-APR-2016
Registration Date: 29-MAY-2016
Expiration Date *: 14-SEP-2018


Carl Blazik,
Director, Technical
Operations & Business Units,
NSF-ISR, Ltd.

NSF International Strategic Registrations

789 North Dixboro Road, Ann Arbor, Michigan 48105 | (888) NSF-9000 | www.nsf-isr.org

Credentials

24/7

Private Ownership

We pick up the
phone after 5pm

513-312-8527

Chad Shell

914-968-4440

Bruce Hack

Owners – Crown Electric

In 2006

Crown Electric built

the **Newest IPB**

factory in North

America



FUTURE HOME OF
CROWN ELECTRIC
Fabricators to the Utility Industry

Design/Build contracting by...



www.ccccontracting.com

(513) 561-6333







In 2010 – in the middle of the worst recession the US has had since the Great Depression **Crown Electric doubled our factory** and added 6,500 sq. ft. of office space.





**And 50,000 sq ft
of fenced in area
for delivery
staging.**



**Crown Electric
is partnered
with some of the
Industry's
largest OEM's**

**Crown Electric
furnishes and
installs IPB for
GE Generator
Circuit Breakers**









**Crown Electric
furnishes and
installs IPB for
Siemens Energy
Services**





**Crown Electric
is the industry's
successor to
Westinghouse
and their Circular
Non Seg Bus Duct**

HIGH AMPERAGE CIRCULAR NON-SEG BUS

“Built Like Iso-Phase; Competitive with Non-Seg”



Crown Electric Engineering and Manufacturing LLC designs, fabricates, and installs Iso Phase Bus and Circular Non-Seg Bus Systems. Crown also maintains and upgrades IPB for most domestic legacy installations.





DANGER
HIGH VOLTAGE
KEEP OUT!









AS40





**Crown Electric
introduced its
own line of
Disconnect
Switches to
30,000 Amps**

















**Crown Electric
developed the
Joule-iious 105
online thermal
monitor**



CROWN ELECTRIC

Joule-ious 105


Iso Phase Bus - On-Line Thermal Monitor

Protect Your Assets

**Iso Phase Bus - Real Time Monitoring
Includes generator and GSU Tx
bushing connections**



- 24/7 monitoring, data logging, annunciation and alarming.
- Infrared temperature sensor provides accurate "no touch" temperature readings.
- Visual indication for critical alarm levels on each phase.
- 15 minute data point trending with 1 year of data storage.
- Wide angular eyeball mounting bracket allows for easy installation and positioning.
- Analog and digital communication available.



Joule-ious 105 - Spec chart

Power Supply: 2A at 120V

Temperature Rating 45C

IR Sensor:

Monitoring Range: 0 – 200C

Accuracy: 2%

Spot Size: 12:1

Options:

- 65C Temperature Rating
- Additional 3 temperature sensors
- Generator MW input (4-20mA)
- Alarm Output



Custom high angular ball mount

Crown Electric offers the **Joule-ious 105** On Line thermal monitoring system for both new and retrofit IPB applications.

The **Joule-ious 105** is a ruggedized, high accuracy infrared, touch-less thermal sensing system.

Joule-ious 105 sensors are mounted on the Iso Phase Bus enclosures pointing at the conductor where it adjoins with the major capital equipment (Generators and GSU transformers).

The **Joule-ious 105** continuously monitors, logs, reports and annunciates IPB temperature at each surveillance point.

Multiple pre-alarm and alarm levels are fully programmable.

Reporting and alarming can be local, remote, wired or wireless.

**Now IPB Temperature Monitoring
is easy and in your hands.**



Rugged and easy
to install sensors

CROWN ELECTRIC ENG. & MFG. LLC IPB and More



Fabricators to the
Utility Industry

- Disconnect Switches
- Generator Breakers
- Full Turn-key Installation
- On-Line Thermal Monitoring
- Engineering Upgrade Studies
- Replacement and Upgraded IPB Coolers

513 539-7394

175 Edison Dr. • Middletown, OH 45044
www.crown-electric.com
sales@crown-electric.com

Crown Electric

is the only North

American IPB

manufacturer with full

factory based field

service and

installation

capabilities.

Crown Electric
the people who
build your IPB,
install your IPB













Crown Electric
provides material
& services to the
nuclear industry



NPI **NUCLEAR POWER** INTERNATIONAL MAGAZINE®

**Nuclear execs discuss the
industry's past, present & future**

**A look inside an iso bus failure at Callaway
Automated callouts reduce wait times
Lasers cut decommissioning dangers**

Photo courtesy: JAEA, Fukushima Nuclear Plant

Departments

ENRICHMENT	3
FUEL FOR THOUGHT	5
NEWS	7
NUCLEAR EVENTS	27


Features


NUCLEAR EXECUTIVE ROUNDTABLE	13
CALLAWAY TURBINE TRIP Failure of Isolated Phase Bus System	21
NUCLEAR PLANT AUTOMATES CALLS FOR HELP	26
USING LASERS IN DECOMMISSIONING	28



07/30/2013

Engineering submittals in 3D CAD





Computerized welding






PANDJIRIS

Fronius

PANDJIRIS

WELDING SUPPLIES





cyclomatic TEAM TRACKER SYSTEM

Fronius

PANDJIRIS
LOUIS MO.

HEAD 1 HEAD 2

120V 60Hz

Paul Vally
1800 44
A







Crown Electric's
computerized
welds are all
capable of being
certified

And Crown
Electric's most
senior design
engineer(s) are
CWI's

Crown

manufactures all
manners of custom
cabinetry, medium
voltage switchgear
& outdoor houses





AMERBA 5400 LB / 2450 KG WLL

AMERBA 5400 LB / 2450 KG WLL

50 KG WLL



MASSACHUSETTS DATA PLATE ADDENDUM

Water Connection Directions	N/A		
Drain Connection Directions	N/A		
Floor Loads: Live	50 psf/100psf S.G. Area	Dead:	10 psf
Electrical Instructions:	Dwg. 080012-E001 thru E012 & C001 – C007		
Electrical Warning	DANGER HIGH VOLTAGE		
Methods of Assembly or Joining Multiple Units	N/A		
Height & Story Limitations	1 story		
Floor Area	14' x 25'		
Min. Side Yard Required for Fire Rating	10ft.		

Crown Electric
designs, fabricates
& installs

**IPB replacement and
uprated coolers –
to nuclear plant size**



Crown Electric
does more
GSU change-outs
than anyone.
And we do them
turn-key





IPB

**Specification
Considerations**

Crown's insulator support windows are a thoughtfully designed system.



There is great
value in having
IPB insulator
support windows
that allow for visual
inspection and
cleaning.



CAUTION
No. 1
















Crown Electric

requires only one (1)
insulator per
support point.







Lets get to know
ANSI/IEEE C29

Iso Phase Bus
insulators
should be
Dew Point rated



Lets look at
C29.1
section 4.6

4.5.2 Precipitation. The precipitation shall be applied in accordance with subsection 1.3.3.2 and Table 1.2 (Practice in USA) of ANSI/IEEE 4-1978.

4.5.3 Preparation of Test Specimen. The preparation of the test specimen shall be in accordance with subsection 1.3.3.2 of ANSI/IEEE 4-1978.

4.5.4 Voltage Application. 75% of the rated wet withstand voltage may be applied in one step and gradually raised to the required value in not less than 5 nor more than 30 seconds.

4.5.5 Test Voltage and Time. The test voltage, which is the rated wet withstand voltage, with appropriate atmospheric corrections applied, shall be held on the test specimen for 10 seconds.

4.5.6 Corrections. Corrections shall be in accordance with 4.2.4, except that no correction shall be made for humidity. The test voltage applicable to existing atmospheric conditions is obtained from the rated withstand voltage, as given for standard atmospheric conditions, by use of the following equation:

$$V = V_s X s$$

where;

V = test voltage, in kilovolts, applied to test specimen

V_s = rated withstand voltage, in kilovolts

s = relative air density

4.6 Low-Frequency Dew Withstand Voltage Tests

4.6.1 Preparation of Test Specimen. The test specimen shall be placed in a chamber having a temperature of from -10°C to -150°C (14°F to 5°F) until the specimen is thoroughly cooled. (Cooling may take 10 to 12 hours.)

4.6.2 Mounting Arrangement. The test specimen shall be mounted in accordance with Section 3 in a test chamber having a temperature of approximately 77°F (25°C). The relative humidity in the test chamber shall be approximately 100%. This may be obtained by passing live steam at atmospheric pressure into the chamber.

4.6.3 Voltage Application. The voltage shall be raised rapidly to dew withstand test voltage, while the test specimen is completely covered with dew. The time to raise the voltage shall be not more than 20 seconds.

4.6.4 Test Voltage and Time. The test voltage, which is the rated dew withstand voltage with appropriate atmospheric corrections applied, shall be held on the test specimen for 10 seconds.

4.6.5 Corrections. Corrections shall be made in accordance with 4.5.6.

4.7 Impulse Flashover Voltage Tests

4.7.1 General. Impulse flashover voltage tests are made under dry conditions only.

4.7.2 Mounting Arrangement. The test-specimen mounting for impulse flashover voltage tests shall be in accordance with Section 3.

4.7.3 Impulse Voltage Wave. All tests shall be made with a 1.2 X 50-microsecond wave, in accordance with ANSI/IEEE 4-1978.

4.7.4 Critical Impulse Flashover Voltage Value. The critical impulse flashover voltage shall be determined in accordance with ANSI/IEEE 4-1978.

4.6 Low-Frequency Dew Withstand Voltage Tests

4.6.1 Preparation of Test Specimen. The test specimen shall be placed in a chamber having a temperature of from -10°C to -150°C . (14°F to 5°F) until the specimen is thoroughly cooled. (Cooling may take 10 to 12 hours.)

4.6.2 Mounting Arrangement. The test specimen shall be mounted in accordance with Section 3 in a test chamber having a temperature of approximately 77°F (25°C). The relative humidity in the test chamber shall be approximately 100%. This may be obtained by passing live steam at atmospheric pressure into the chamber.

4.6.3 Voltage Application. The voltage shall be raised rapidly to dew withstand test voltage, while the test specimen is completely covered with dew. The time to raise the voltage shall be not more than 20 seconds.

4.6.4 Test Voltage and Time. The test voltage, which is the rated dew withstand voltage with appropriate atmospheric corrections applied, shall be held on the test specimen for 10 seconds.

4.6.5 Corrections. Corrections shall be made in accordance with 4.5.6.

Lets look at
C29.1 0
Table 2

Table 1			
Metric Equivalents			
Inches	Millimeters	Inches	Millimeters
1/32	0.8	4-1/2	114
1/2	13	5	127
9/16	14	6	152
5/8	16	6-1/4	159
3/4	19	7	178
7/8	22	7-1/2	191
1	25.4	8	203
1-1/8	29	8-1/2	217
2	51	9	229
2-1/2	64	10-1/2	267
3	76	12	305
3-1/2	89	15	381
3-3/4	95	16-1/2	419
4-1/4	108		

Table 2			
Electrical Characteristics			
Nominal Voltage Rating (kV)	Withstand Test Voltage (kV)		
	Impulse	Low-Frequency Dry, One Minute	Dew, 10 Seconds
2.4	45	15	10
4.8	60	19	15
7.2	75	26	24
13.2	95	38	26
14.4	110	50	30
23.0	125	60	40
23.0	150	60	40
34.5*	150	80	--
34.5*	200	80	--

*The 34.5-kV insulator units are for bus supports and front-connected devices only.

Table 3				
Mechanical Characteristics of Strength Class A-10				
Nominal Voltage Rating (kV)	Cantilever* (Pounds)	Torsional (Inch-Pounds)	Tensile (Pounds)	Compression (Pounds)
2.4	750	1500	11500	10000
4.8	750	1500	1500	10000
7.2	750	1500	1500	10000

*Cantilever strength ratings are given 2-1/2 inches above the cap.

Table 2**Electrical Characteristics**

Nominal Voltage Rating (kV)	Withstand Test Voltage (kV)		
	Impulse	Low-Frequency Dry, One Minute	Dew, 10 Seconds
2.4	45	15	10
4.8	60	19	15
7.2	75	26	24
13.2	95	36	26
14.4	110	50	30
23.0	125	60	40
23.0	150	60	40
34.5*	150	80	--
34.5*	200	80	--

*The 34.5-kV insulator units are for bus supports and front-connected devices only.



Dew Point rated
insulators mean
you never need
pressurization and it
is totally passive.

No leaks.

No pressurization
systems to maintain.

No loss of BIL.

No down time

Never accept
pressurization
without applying an
evaluation
penalty.



The **Westinghouse slider mounting design** allows insulators to harmonize with thermal expansion and better dissipate short circuit forces.













Windows hold space heaters and can be field upgraded well after initial install.





CA1002

Windows accept
electric conduit
connections on
either side.



Windows use
“O” rings
not gaskets.







Windows

hold drain plugs
and breathers



Now
lets discuss the
IPB's Enclosure

I have two questions
for you that we can
discuss in more
depth at some later
time off-line.

1 – Did you know that IPB enclosure current is more or less equal to the conductor current ?

For all practical purposes – IPB is a transformer with a 1:1 turns ratio.



Your specs could well improve the IPB product you get if they clearly state that enclosure max. temperature of 80 degree C shall be calculated at 100 % of the same maximum current value as the IPB conductor

2 – If you evaluate and charge for losses in transformers – why don't you do the same evaluation for IPB ?

It's the same electrons and the same heat (energy) lost from the production process.

Something to notice
on

**Enclosures for
connecting IPB to
capital equipment.**



Notice the
Covers



See how they
mount?





Those raised welded
mounting frames
takes:

Engineering
Drafting
Fabrication
Welding
Finishing

Those raised welded
mounting frames...

\$ Cost money \$

If you want them.
You need to
specify them.

BTW

Shipping sections



#'s of shipping sections


Points of break in
shipping sections

All cost installation \$\$'s

Consider discussing this
issue with your bidders
during the evaluation process

As we wind down-
allow me to point out
**two more things worth
knowing about...**

1 – Shunts







Shunts are made of bundles of very thin laminates of aluminum. And they move (often).



The shunt bundles should be welded on the inside – not the outside. A broken laminate can bend outward toward the ground plane !





2 – know your connection points. They should be quality **silver plated**. The silver plating should be per a certified procedure.



Spec 3-5 mils.
And vendor should
provide certification
with their bid.

NEVER accept
wipe-on
silver plating.

Silver Plating
A Special Process at
Crown Electric



When Crown Electric began using the Electrodeposited silver plating machines, the instructions with the machines were vague in what was needed to meet the standards of our industry.


The instructions showed how to plate, but lacked the information on how much or how long to deposit the silver to achieve the desired results.

We researched and purchased the standards that apply to the process. The first standard is for adhesion ASTM B571-97; we needed to know that the silver stayed in place. The second is the standard for thickness ASTM B700-08.

According to the standard ASTM B700-08 the thickness for electrical contact connectors of limited wear is 2.5 micrometers. At Crown we wanted a margin greater than 2.5 μ m to ensure supply of a consistent and superior product. So we embarked on the task of preparing coupons and plating at incremental times, then sending them out to a second party laboratory for testing and documented results.


Because the testing process results in destruction of the samples, we needed to validate our process and document a procedure to set in place for our quality standards as well as to meet our ISO program requirements.

The process began by making the coupons out of the material we use for our product. We prepared them for plating as standard process and recorded the rub time per coupon, then sent the coupons to the lab. Our first couple of coupons passed the adhesion tests.




After burnishing test neither specimen developed blisters, lifting or peeling. This satisfies the requirement in paragraph 4.1 of ASTM B571.

However one fell short on thickness and the other was predominantly at the standard thickness with some valleys that showed under the microscope to be less than desirable.




Silver coating is discontinuous and measured thickness is less than the 2.5 μm minimum thickness specified in ASTM B700. (Average ~ 1 μm)



Silver coating is continuous and measured thickness is between 1.5 - 5 μm, with a predominant thickness of ~ 2.5 μm.

Then we prepared and plate additional coupons with a longer rub time. They were sent to the lab for evaluation.

We were pleased with our test results; again the adhesion test satisfied the standard and the thickness tests came out far exceeding the standards hallmark.



Silver coating is continuous and predominant thickness is between 10 and 20 μm .

The information from the testing has been written into a Crown Electric ISO Silver Plating Procedure for use in-house, as well as on customer sites should the need arise.



We now have second party laboratory results which show that Crown's silver plating exceeds the standards and complements the Crown Electric products high standards.

REPORT NO.: K12066433-1	DATE: 6/19/2012	CUSTOMER: Crown Electric	P.O.#: S12-0089	AUTHORIZED BY: David DeWitt
SAMPLES RECEIVED AS: (2) Aluminum samples with silver coating Accutek ID#6433-1: Labeled 1 of 2 by client Accutek ID#6433-2: Labeled 2 of 2 by client				SAMPLED & TESTED BY: R. Frischmuth

MICROSCOPIC EVALUATION

EVALUATE PER: ASTM B700
PROCEDURE: MET-PRP-5410
 MET-EXM-5400
MAGNIFICATION: 1000X
EQUIPMENT: ZEISS AXIOVERT 40MAT SN 254

RESULTS




Photo 1 shows typical field of cross section of 6433-1. Silver coating is discontinuous and measured thickness is less than the 2.5 μm minimum thickness specified in ASTM B700. (Average $\sim 1 \mu\text{m}$)

REPORT NO.: K12066433-1	DATE: 6/19/2012	CUSTOMER: Crown Electric	P.O.#: S12-0089	AUTHORIZED BY: David DeWitt
SAMPLES RECEIVED AS: (2) Aluminum samples with silver coating Accutek ID#6433-1: Labeled 1 of 2 by client Accutek ID#6433-2: Labeled 2 of 2 by client				SAMPLED & TESTED BY: R. Frischmuth

MICROSCOPIC EVALUATION




Photo 2 shows typical field of cross section of 6433-2. Silver coating is continuous and measured thickness is between 1.5 - 5 μm , with a predominant thickness of ~ 2.5 μm .

REPORT NO.: K12066433-1	DATE: 6/19/2012	CUSTOMER: Crown Electric	P.O.#: S12-0089	AUTHORIZED BY: David DeWitt
SAMPLES RECEIVED AS: (2) Aluminum samples with silver coating Accutek ID#6433-1: Labeled 1 of 2 by client Accutek ID#6433-2: Labeled 2 of 2 by client				SAMPLED & TESTED BY: R. Frischmuth

MICROSCOPIC EVALUATION




Photo 3 shows worst case field of cross section of 6433-2. Minimum measured silver coating thickness is $\sim 1.5 \mu\text{m}$.

WE HEREBY CERTIFY THE RESULTS ABOVE TO BE THE TRUE RESULTS OBTAINED ON THE SAMPLES TESTED. CALIBRATION SYSTEM IS MAINTAINED IN ACCORDANCE WITH ISO 17025:2005.

EVALUATED BY:

John P. McClay

John P. McClay, PE, CWI
President-Accutek Testing Laboratory

REPORT NO.: K12066433-2	DATE: 6/19/2012	CUSTOMER: Crown Electric	P.O.#: S12-0089	AUTHORIZED BY: David DeWitt
SAMPLES RECEIVED AS: (2) Aluminum samples with silver coating Accutek ID#6433-1: Labeled 1 of 2 by client Accutek ID#6433-2: Labeled 2 of 2 by client				SAMPLED & TESTED BY: R. Frischmuth

BURNISHING TEST

EVALUATE PER: ASTM B571
PROCEDURE: ASTM B571. RUBBED TOOL OVER AREA FOR APPROXIMATELY 15 SECONDS.
TOOL: 1/4" STEEL ROD WITH HEMISPHERICAL END

RESULTS




Photo 1 (top) shows 6433-1 and photo 2 (bottom) shows 6433-2 after burnishing test. Neither specimen developed blisters, lifting or peeling. This satisfies the requirement in paragraph 4.1 of ASTM B571.

WE HEREBY CERTIFY THE RESULTS ABOVE TO BE THE TRUE RESULTS OBTAINED ON THE SAMPLES TESTED. CALIBRATION SYSTEM IS MAINTAINED IN ACCORDANCE WITH ISO 17025:2005.

EVALUATED BY:

John P. McCloy
John P. McCloy, PE, CWI
President-Accutek Testing Laboratory

I guess the point I'm
trying to make is –

Iso Phase Bus
may be boring

But there are
**engineering
differences**
to be cognizant of

- Dew point rated stand off supports

- Dew point rated stand off supports
- Forced
pressurization
should be
penalized

- Dew point rated stand off supports
- Forced pressurization should be penalized
- Insulator in-situ visibility and accessibility should be positively evaluated

- Dew point rated stand off supports
- Forced pressurization should be penalized
- Insulator in-situ visibility and accessibility should be positively evaluated
- **Welding should be able to be certified**

- Dew point rated stand off supports
- Forced pressurization should be penalized
- Insulator in-situ visibility and accessibility should be positively evaluated
- Welding should be able to be certified
- **Enclosures should have welded raised frames for bolting on covers.**

- Dew point rated stand off supports
- Forced pressurization should be penalized
- Insulator in-situ visibility and accessibility should be positively evaluated
- Welding should be able to be certified
- Enclosures should have welded raised frames for bolting on covers.
- **Enclosure's
amperage should
be specified**

- Dew point rated stand off supports
- Forced pressurization should be penalized
- Insulator in-situ visibility and accessibility should be positively evaluated
- Welding should be able to be certified
- Enclosures should have welded raised frames for covers
- Enclosures amperage should be specified
- **IPB losses should be evaluated**

Always remember





175 Edison Dr. • Middletown, OH 45044

www.crown-electric.com

sales@crown-electric.com

513 539-7394